

SONI Grid Code Modification Register: 10/05/2023

ID	Proposer	Company	Date of Proposal	Description	Impact on Grid Code	Category	GCRP Presentation Date	Status	Date of UR Approval	Notes	Link to Approval
SPID_01_2013	TBC	TBC	2013	TBC	Intro, Glossary and Definitions, PC6.3.3, PCA3.4, PCB3.3, CC.8.5.7, CC12, CC13, OC2, OC11, SDC1 and SDC2	Standard	TBC	UR Approved	15/04/2015	Summary of 2013 mods by Regulator. Largest change to CC13 regarding Demand Side Unit MW, min off time and method of aggregation	TBC
SPID 141015	Marie-Therese Campbell	SONI	14/10/2015	Notice of Intent to Disconnect due to Retirement	Planning Code - addition of PC6.1.6	Standard	TBC	UR Approved	TBC	Provide clarity around the retirement of plant in Northern Ireland and align the requirements with the Ireland Grid Code.	TBC
SPID 150216 / MPID 268	Raymond Skillen	SONI	01/11/2016	To define Outrun Availability as published in the SEMC Decision Paper SEM-15-071 in Sept 2015.	SDC1.4.3.2, SDC1.4.3.4 and SDC1.4.3.9	Standard	02/12/2015	UR Approved	16/11/2016	TBC	TBC
SPID 030217	Alastair Cooke	SONI	03/02/2017	Metering Code – Advanced Meter Reconciliation Process	Metering Code	Standard	TBC	UR Approved	TBC	New defined term Relevant Meter Operator definition. Intends to provide a more efficient and reliable process for Advanced Meter reconciliation	TBC
MPID-271	Alan Kennedy	SONI	05/05/2017	ISEM modifications	TBC	Standard	TBC	UR Approved	11/08/2017	TBC	TBC
SPID 260619	Daniel McSwiggan	SONI	11/06/2019	Integration of the RfG requirements into the Grid Code	Sections in Articles 14.3 - 21.3 excluding 17	Standard	TBC	UR Approved	TBC	Derogations were required before full integration achieved	TBC
SPID 01_2020	Stephen Brownlees	EP Kilroot Limited	09/10/2020	Modify maximum continuous rating requirement in SONI Grid Code	Pg 151 and 158	Standard	16/12/2020	Open		Changes requirement of output "no greater than the lower of 80MW or 40% of its MCR" to remove the 80MW	
SPID 02_2021	Brian Mongan	Powerhouse	05/05/2021	Modify minimum aggregation value in SONI Grid Code	Pg 377-421	Standard	02/11/2021	Dormant	08/06/2022	Change the minimum registered capacity of AGU and DSU from 4MW to 1MW	
SPID 01_2021	Rowan Griffin	SONI	01/10/2021	Meter Code Changes	Metering Code	Standard	02/11/2021	UR Approved	21/03/2022	Outdated sections of code revised to bring in line with current standards	TBC
SPID 03_2021	Paul Troughton	DRAI	13/10/2021	Maximum Down Time Reduction	CC13.1	Standard	02/11/2021	Dormant	15/06/2022	Remove the current requirement for 2 hours Maximum Down Time and have no minimum requirement	
SPID 01_2022	Conor O'Byrne	SONI	03/10/2022	RoCoF changes needed to manage future operation of All-Island Power System	CC5.3, CC.8.8.4(b), CC.5.1.1.5.6, CC.5.1.2.4.4	Standard	02/10/2012	Open			
SPID 02_2022	Catriona Kelly	SONI	09/11/2022	To update the PV signalling requirements in line with best practice	PPM setting schedule	Standard	09/11/2022	Open			