



SONI Monthly Availability Report – October 2022

Availability report for October 2022¹

Definitions

Availability: The maximum generation of electricity which generators can achieve during that period.

Forced: For any reduction in **Availability** not approved in advance with the Generation Outage Planning Team (GOP) (including trips, outage overruns, urgent repairs, partial outages etc..).

Scheduled: Scheduled generator outage approved by the SONI GOP.

Ambient: Derating of generator capacity due to a change in temperature conditions.

Maximum Export Capacity (MEC): The value (in MW and/or MVA) provided in accordance with the User's **Connection Agreement** or DNO Demand Customer's **DNO Connection Agreement**.

Connection Agreement: The bilateral agreement between the TSO and the User, which contains the detail specific to the User's connection to the Transmission System.

Demand Side Unit (DSU): An individual demand site or aggregated demand site with a **DSU MW Capacity** of at least 4 MW.

DSU MW Capacity: The maximum change in active power that can be achieved by a DSU on a sustained basis for the duration of the DSU's maximum down time by totalling the potential increase in on-site active power generation and the potential decrease in on-site active power demand at each individual demand site.

Average Monthly Availability: Average **Availability** over the past month.

365-day Rolling Availability: Average **Availability** over the past year.

HOW TO CONTACT US

General Queries

Email: info@soni.ltd.uk

www.soni.ltd.uk

¹ Based on EDIL (Electronic Dispatch Instruction Logger) declarations.

Table 1: Unit-by-Unit Average Monthly Availability Conventional Units & Aggregated Generator Units – October 2022

Unit-by-Unit Average Monthly Availability – October 2022						
Company	Unit	MEC (MW)	Monthly Availability %	Monthly Forced %	Monthly Scheduled %	Monthly Ambient %
EPUK	Ballylumford - B10	94	91.1	0.0	0.0	8.9
	Ballylumford - B21	249	86.4	0.0	10.7	2.8
	Ballylumford - B22	249	96.8	0.1	0.0	3.1
	Ballylumford - BGT1	58	0.0	100.0	0.0	0.0
	Ballylumford - BGT2	58	99.5	0.5	0.0	0.0
	Kilroot - KGT1	29	96.7	3.3	0.0	0.0
	Kilroot - KGT2	29	96.7	3.3	0.0	0.0
	Kilroot - KGT3	42	33.4	66.6	0.0	0.0
	Kilroot - KGT4	42	88.7	11.3	0.0	0.0
	Kilroot - KPS1 Coal	175	21.3	32.0	46.7	0.0
	Kilroot - KPS1 Oil	256	14.1	39.2	46.7	0.0
	Kilroot - KPS2 Coal	175	71.9	28.1	0.0	0.0
	Kilroot - KPS2 Oil	258	48.1	51.9	0.0	0.0
Contour Global	AGU - CGA	12.1	50.0	50.0	0.0	0.0
ESB	Coolkeeragh - C30	408	68.0	0.6	25.1	6.3
	Coolkeeragh - CG8	53	99.9	0.2	0.0	0.0
Empower	AGU - EMP	12.8	100.0	0.0	0.0	0.0
Evermore	Lisahally - LPS	18	85.0	15.1	0.0	0.0
lpower	AGU	57.7	89.7	10.3	0.0	0.0

Table 2: Unit-by-Unit Average Monthly Availability Demand Side Units – October 2022

Unit-by-Unit Average Monthly DSU Availability – October 2022			
Company	Unit	DSU MW Capacity	Monthly Availability %
AC Auto NI	ACA	7.6	75.0
AE_DSU_NI	AEA	8.4	34.8
Energy Trading Ireland	ETB	5.0	20.1
	ETC	4.5	0.0
	ETD	5.1	1.8
	ETR	4.0	15.2
Electricity Exchange NI	VN1	6.8	8.6
Endeco Technologies	ECA	21.8	27.0
	ECB	6.3	17.8
Powerhouse Ltd	PH1	19.5	32.9
	PH2	13.5	36.6
lpower	ID1	4.7	20.0
	ID2	5.2	22.6

Whilst it strives to ensure as high a level of accuracy as possible, SONI makes no warranties or representations of any kind with respect to the content of this report (including without limitation its quality, accuracy, and completeness.) and SONI accepts no liability for any reliance on the information presented here.

Table 3: NI System Total Average Monthly Availability – October 2022

	Monthly Availability %	Monthly Forced %	Monthly Scheduled %	Monthly Ambient %
NI Conventional Total Average Availability	70.4	21.7	6.8	1.1
NI DSU Total Average Availability	24.0	N/A	N/A	N/A

Table 4: Unit-by-Unit 365 Day Rolling Availability Conventional Units & Aggregated Generator Units – 1st November 2021 to 31st October 2022

Unit-by-Unit 365 Day Rolling Availability – October 2022						
Company	Unit	MEC (MW)	Annual Availability %	Annual Forced %	Annual Scheduled %	Annual Ambient %
EPUK	Ballylumford - B10	94	88.0	1.0	2.1	8.9
	Ballylumford - B21	249	92.5	1.0	2.6	3.8
	Ballylumford - B22	249	93.3	0.4	2.5	3.7
	Ballylumford - BGT1	58	48.5	35.0	16.5	0.0
	Ballylumford - BGT2	58	94.7	5.2	0.1	0.0
	Kilroot - KGT1	29	94.4	4.5	1.1	0.0
	Kilroot - KGT2	29	87.4	7.6	5.0	0.0
	Kilroot - KGT3	42	79.9	16.7	3.4	0.0
	Kilroot - KGT4	42	78.8	19.4	1.8	0.0
	Kilroot - KPS1	256	58.7	37.5	3.8	0.0
	Kilroot - KPS2	258	38.3	29.3	32.4	0.0
Contour Global	AGU - CGA	12.084	86.7	13.3	0.0	0.0
ESB	Coolkeeragh - C30	408	82.2	1.8	10.4	5.5
	Coolkeeragh - CG8	53	96.4	1.0	2.6	0.0
Empower	AGU - EMP	12.755	94.1	0.0	5.9	0.0
Evermore	Lisahally - LPS	18	81.1	18.9	0.0	0.0
lpower	AGU	57.717	84.5	15.5	0.0	0.0

Table 5: Unit-by-Unit 365 Day Rolling Availability Demand Side Units – 1st November 2021 to 31st October 2022

Unit-by-Unit 365 Day Rolling DSU Availability – October 2022			
Company	Unit	DSU MW Capacity	Monthly Availability %
AC Auto NI	ACA	7.6	75.0
AE_DSU_NI	AEA	8.4	39.7
Energy Trading Ireland	ETB	5.0	12.8
	ETC	4.5	0.0
	ETD	5.1	2.7
	ETR	4.0	14.0
Electricity Exchange NI	VN1	6.8	5.9
Endeco Technologies	ECA	21.8	32.3
	ECB	6.3	1.8
Powerhouse Ltd	PH1	19.5	29.6
	PH2	13.5	30.4
lpower	ID1	4.7	20.0
	ID2	5.2	27.2

Table 6: 365 Day Rolling NI System Total Average Availability – 1st November 2021 to 31st October 2022

	Annual Availability %	Annual Forced %	Annual Scheduled %	Annual Ambient %
NI Conventional Total Average Availability	81.2	12.2	5.3	1.3
NI DSU Total Average Availability	22.4	N/A	N/A	N/A

Whilst it strives to ensure as high a level of accuracy as possible, SONI makes no warranties or representations of any kind with respect to the content of this report (including without limitation its quality, accuracy, and completeness.) and SONI accepts no liability for any reliance on the information presented here.